

WATER PIPE REPLACEMENT (217) VIDEO INSPECTION CHECKLIST

Permit Number: _____ Address: _____

INTRODUCTION:

All Water Pipe Replacement Video Inspections must begin with the following:

- 1. Providing close-up of address numbers
- 2. State your name, company, date & time
- 3. Permit Card

WATER PIPE REPLACEMENT:

Video must include:

- 1. Pressure test
 - Leak free installation can be confirmed two ways:
 - 1. Show 80 psi gauge (show gauge at beginning and end of video)
 - 2. Run faucet to show that system is pressurized at normal operating pressure and video all joints
- 2. Nail plates
- 3. Hammer arrestor (DW,WM, Icemaker)
- 4. Hot water to DW
- 5. Pipe support every 4 feet
- 6. Vacuum breaker on hose bibb
- 7. Protective sleeve through masonry
- 8. Piping not in contact with sharp objects/edges
- 9. Grommets for steel stud penetrations
- 10. No kinks or bends beyond 90 degrees (flexible pipe)

I _____ (printed name of submitter), as an authorized person to upload video inspection files in accordance with Collier County Virtual Inspection procedures. I have reviewed the video and have checked off all applicable boxes above prior to uploading to BOX, as required by Collier County requirements.

Signature

Date