



NOTES:

1. MJ TAPPED CAP WITH HOSE BIBB IS TO BE REMOVED AFTER INITIAL BACTERIOLOGICAL CLEARANCE AND PRIOR TO WATER MAIN ACCEPTANCE.
2. SEE TECHNICAL SPECIFICATIONS SECTION 331200 FOR GATE VALVE AND VALVE BOX REQUIREMENTS.
3. ALL COMPONENTS THAT COME INTO CONTACT WITH DRINKING WATER SHALL CONFORM TO NSF STANDARD 61.

**TEMPORARY BLOWOFF  
ASSEMBLY WITH BACTERIAL  
SAMPLING POINT DETAIL** NTS

REVISION DATE:

MAY 2013



**COLLIER COUNTY**  
PUBLIC UTILITIES DIVISION  
3301 E. TAMiami TRAIL  
NAPLES, FLORIDA 34112

SHEET NO.

W-1