

WATER HEATER CHANGE-OUT VIDEO INSPECTION CHECKLIST

Permit Number: _____ Address: _____

INTRODUCTION:

All Water Heater Change Out Video Inspections must begin with the Following:

- 1. Providing close-up of address numbers
- 2. State your name, company, date & time
- 3. Permit Card

GAS:

Video must include:

- 1. Flue clearance from combustibles
- 2. H&C water lines for clearance from flue
- 3. Flue pipe for required self-tapping screws
- 4. Double wall flue pipe through penetrations
- 5. Check for draft (if possible)
- 6. Flue terminus
- 7. Soap test

ELECTRIC:

Video must include:

- 1. Hard wired
- 2. Disconnect within 50 ft. with clear sight to breaker panel
- 3. Lock out tag out, if breakers in another room

GAS/ELECTRIC:

Video must include:

- 1. Relief drip
- 2. Drip pan
- 3. Drip pan drain
- 4. Expansion tank supported
- 5. TP valve if no expansion tank
- 6. No water leaks
- 7. Check gallons reflect description on permit
- 8. Check for level and stability
- 9. Accessible for maintenance
- 10. Shut off valve on cold water feed

I _____ (printed name of submitter), as an authorized person to upload video inspection files in accordance with Collier County Virtual Inspection procedures. I have reviewed the video and have checked off all applicable boxes above prior to uploading to BOX, as required by Collier County requirements.

Signature

Date